

Maheshkumar R. Mod

Regional Fire Officer



Gandhinagar Municipal Corporation

Fire and Emergency Service

Nr. Jilla Panchayat, 1st Floor,

Sector-17, Gandhinagar

Mobile No.+91 94279 55551

Email :-gmcfire101@gmail.com

" WE SERVE TO SAVE "

GFES/FIRE NOC/R-5/027/2022

Dt. 25/01/2022


Fire Safety Certificate

Certified that the **Anand Niketan Sughad, S.P ring road, B/h Sandesh Farm ,Gandhinagar**, comprised Of School (B+G+5 Floor) owned/occupied by **Anand Utthan Trust** have complied with the fire prevention and fire safety requirements in accordance with section 18 and verified by the officers concerned of Fire Service on Dt.20-01-2022 in the presence of Myth Fire Services and the School is fit for occupancy with effect from for a period of **(from Dt.25-01-2022 to Dt.24-01-2025)** years in accordance with rules and subject to compliance of any specific laid by the issuing officer.

નોંધ- ઈમારતનો ઉપયોગ બી.યુ. પરમિશન મુજબ કરવાનો રહેશે અન્યથા સદર સર્ટીફિકેટ રદ ગણવામાં આવશે.

Place Gandhinagar

Issued Dt. 25/01/2022



Regional Fire Officer

Fire and Emergency Services

Gandhinagar Municipal Corporation

DD NO. 668587 (Kotak Mahindra Bank)

DD Date. 24/01/2022

DD Fees. 4250.00 (New)

Bitasta Bhattacharya.
Principal

Anand Niketan Sughad
Gandhinagar - 382424

92.
Managing Trustee/Trustee
Anand Utthan Trust

- 1) The main gate is to be wide enough to let fire vehicle in the campus and should be kept open.
- 2) Fire equipment to be kept handy and in a manner easily accessible.
- 3) All emergency numbers should be displayed outside the office.
- 4) The primary training will have to be given to all employees to use the fire extinguishing system in difficult circumstances and the certificate will have to be obtained and submitted.
- 5) Students studying in the school should also be given basic training on how to rescue in case of fire.
- 6) Roads leading to the school must be kept open.
- 7) Use of basement(If)/Building must be done as per B.U. permission.
- 8) No road or dome of any kind should be built on the roof.
- 9) No more than 40 students in a class room.
- 10) Class room and Evacuation routes should be kept open and should not be blocked.
- 11) There should be no storage of scrap material in school campus.
- 12) The school shall comply with all fire and safety regulations and guidelines issued by the concerned and competent authority.
- 13) In any case, care should be taken to ensure that ventilation and exit routes are directly or indirectly accessible for all.
- 14) The canteen shall be kept away from the school building

Bitasta Bhattacharya.
Principal
Anand Niketan Sughad
Gandhinagar - 382424


Managing Trustee/Trustee
Anand Utthan Trust